



**Model W350 Roll-Up Door**




MODEL	DOOR WIDTH	MAXIMUM DOOR HEIGHT	MAXIMUM POSITIVE PSF	MAXIMUM DOOR HEIGHT	DESIGN LOAD POSITIVE PSF	DESIGN LOAD NEGATIVE PSF
W350	16'-0"	16'-0"	41.8	16'-0"	41.8	-41.7



Date of Test Oct 15, 2018

Non Impact Pressure Test

Up to 16'-0" Opening Width  
 16'-3" Sheet Width



Note: Windlocks from 1345 Galv Steel & Riveted to Alternate Corrugations with 2 Steel Rivets



**F-2689**  
 STATE OF TEXAS  
 BRIAN D. CAMPBELL  
 93794  
 LICENSED PROFESSIONAL ENGINEER  
 114571